

Report Date: February 12, 2021

Project: Cuyahoga County  
Courthouse Square

Inspector(s):

- Julianne Gue, Certified Technician

Inspection and Test Date(s):

- February 1 -February 4, 2021

Duct Fabricators, Inc. "Fire Safety Division" inspected the Twenty-four (24) fire dampers noted on the following sheets for proper installation. The dampers were then tested and photographed in the "open" and "closed" positions to confirm that they were functioning as designed.

All of the dampers passed the inspection and functional testing.

NOTES: NFPA 80 and NFPA 105 require newly installed dampers to be inspected and tested one year after initial installation. Thereafter, dampers located in patient care facilities are to be inspected and tested every six years.

Additionally, the information contained herein verified whether the dampers were functional at the time of testing. This verification process does not represent any form of a guarantee that the dampers will properly perform in the future.

Duct Fabricators, Inc.  
 883 Addison Rd. Cleveland, Ohio  
 P: 216-391-2400 F:216-391-2492



Fire / Smoke / Fire & Smoke Damper  
Composite Inspection Report

	<u>FD/SD/FSD</u>	<u>I.D.#</u>	<u>Size</u>	<u>Manufacturer</u>	<u>Model</u>	<u>Visual</u>	<u>Functional</u>	<u>Comments</u>
1	FD	CHS-P-Toilet Ex	30x20	Prefco Products	Uknown	Pass	Pass	Penthouse
2	FD	CHS-P-OA	36x30	Prefco Products	Uknown	Pass	Pass	Penthouse
3	FD	CHS-P-Gen Ex	20x30	Prefco Products	Uknown	Pass	Pass	Penthouse
4	FD	CHS-7-Toilet Ex	14x20	Prefco Products	Uknown	Pass	Pass	None
5	FD	CHS-7-OA	24x10	Prefco Products	Uknown	Pass	Pass	None
6	FD	CHS-7-Gen Ex	14x10	Prefco Products	Uknown	Pass	Pass	None
7	FD	CHS-6-Toilet Ex	14x10	Prefco Products	Uknown	Pass	Pass	None
8	FD	CHS-6-OA	24x10	Prefco Products	Uknown	Pass	Pass	None
9	FD	CHS-6-Gen Ex	14x10	Prefco Products	Uknown	Pass	Pass	None
10	FD	CHS-5-Toilet Ex	14x10	Prefco Products	Uknown	Pass	Pass	None
11	FD	CHS-5-OA	24x10	Prefco Products	Uknown	Pass	Pass	None
12	FD	CHS-5-Gen Ex	14x10	Prefco Products	Uknown	Pass	Pass	None
13	FD	CHS-4-Toilet Ex	14x10	Prefco Products	Uknown	Pass	Pass	None
14	FD	CHS-4-OA	24x10	Prefco Products	Uknown	Pass	Pass	None
15	FD	CHS-4-Gen Ex	14x10	Prefco Products	Uknown	Pass	Pass	None
16	FD	CHS-3-Toilet Ex	14x10	Prefco Products	Uknown	Pass	Pass	None
17	FD	CHS-3-OA	24x10	Prefco Products	Uknown	Pass	Pass	None
18	FD	CHS-3-Gen Ex	14x10	Prefco Products	Uknown	Pass	Pass	None
19	FD	CHS-2-Toilet Ex	14x10	Prefco Products	Uknown	Pass	Pass	None
20	FD	CHS-2-OA	24x10	Prefco Products	Uknown	Pass	Pass	None

Inspector: Julie Gue  
Inspection Dates: 2/2/2021-2/4/2021  
Facility: Courthouse Square

SA = Supply Air  
 OA = Outside air  
 EX = Exhaust Air  
 FD = Fire Damper  
 SD = Smoke Damper  
 FSD = Fire/Smoke Damper

Duct Fabricators, Inc.  
 883 Addison Rd. Cleveland, Ohio  
 P: 216-391-2400 F: 216-391-2492



Fire / Smoke / Fire & Smoke Damper  
Composite Inspection Report

	<u>FD/SD/FSD</u>	<u>I.D.#</u>	<u>Size</u>	<u>Manufacturer</u>	<u>Model</u>	<u>Visual</u>	<u>Functional</u>	<u>Comments</u>
21	FD	CHS-2-Gen Ex	14x10	Prefco Products	Uknown	Pass	Pass	None
22	FD	CHS-B-Toilet Ex	14x10	Prefco Products	Uknown	Pass	Pass	Basement
23	FD	CHS-B-OA	24x14	Prefco Products	Uknown	Pass	Pass	Basement
24	FD	CHS-B-Gen Ex	14x10	Prefco Products	Uknown	Pass	Pass	Basement
25								
26								
27								
28								
29								
30								
31								
32								
33								
34								
35								
36								
37								
38								
39								
40								

Inspector: Julie Gue  
Inspection Dates: 2/2/2021-2/4/2021  
Facility: Courthouse Square

SA = Supply Air      FD = Fire Damper  
 OA = Outside air    SD = Smoke Damper  
 EX = Exhaust Air     FSD = Fire/Smoke Damper