

Report Date: October 20, 2020

Project: Cuyahoga County
Jane Edna Hunter Building

Inspector(s):

- Julianne Gue, Certified Technician

Inspection and Test Date(s):

- June 16-17, 2020
September 30, 2020

Duct Fabricators, Inc. "Fire Safety Division" inspected the Twelve (12) fire dampers noted on the following sheets for proper installation. The dampers were then tested and photographed in the "open" and "closed" positions to confirm that they were functioning as designed.

All of the dampers passed the inspection and functional testing.

NOTES: NFPA 80 and NFPA 105 require newly installed dampers to be inspected and tested one year after initial installation. Thereafter, dampers located in patient care facilities are to be inspected and tested every six years.

Additionally, the information contained herein verified whether the dampers were functional at the time of testing. This verification process does not represent any form of a guarantee that the dampers will properly perform in the future.

Duct Fabricators, Inc.
 883 Addison Rd. Cleveland, Ohio
 P: 216-391-2400 F: 216-391-2492



Fire / Smoke / Fire & Smoke Damper
Composite Inspection Report

	<u>FD/SD/FSD</u>	<u>I.D.#</u>	<u>Size</u>	<u>Manufacturer</u>	<u>Model</u>	<u>Visual</u>	<u>Functional</u>	<u>Comments</u>
1	FD	AHU1-R	64x40	Safe Air	Unknown	Pass	Pass	None
2	FD	AHU1-S	64x40	Safe Air	Unknown	Pass	Pass	None
3	FD	AHU2-R	60x40	Safe Air	Unknown	Pass	Pass	None
4	FD	AHU2-S	64x40	Ruskin	IBD20	Pass	Pass	None
5	FD	AHU3-R	110x30	Ruskin	IBD20	Pass	Pass	None
6	FD	AHU3-S	72x30	Safe Air	Unknown	Pass	Pass	None
7	FD	AHU4-R	110x30	Safe Air	Unknown	Pass	Pass	None
8	FD	AHU4-S	72x30	Safe Air	Unknown	Pass	Pass	None
9	FD	AHU5-R	114x36	Safe Air	Unknown	Pass	Pass	None
10	FD	AHU5-S	110x30	Safe Air	Unknown	Pass	Pass	None
11	FD	AHU6-R	114x36	Safe Air	Unknown	Pass	Pass	None
12	FD	AHU6-S	110x30	Safe Air	Unknown	Pass	Pass	None

Inspector:

Julie Gue

SA = Supply Air

FD = Fire Damper

Inspection Dates:

June 16 and 17 of 2020. September 30, 2020

RA = Return Air

Facility:

Jane Edna Hunter