

## CUYAHOGA COUNTY DAMPER INSPECTION REPORT

**Date of Inspection**

2022-11-02

**Facility Location**

Bedford City Jail

**Damper Location**

2<sup>nd</sup> Floor Corridor

**Inspector Name**

Dan Tulcewicz

**Damper I.D. #**

FD-5

**Damper Type**

Vertical Fire Damper

**Damper Size**

30x10

**Damper Manufacturer**

Greenheck

**Damper Model #**

FD150AV

**Fusible Link Temperature**

165 Degrees

**Access Door Size**

16x16

**Pass / Fail / Abandoned**

Pass

**Comments / Corrections**

None

**Picture of Damper in Open Position**



**Picture of Damper in Closed Position**



**Picture of Damper I.D. Label**

