

VISUAL CUYAHOGA COUNTY DAMPER INSPECTION REPORT

Date of Inspection

2023-03-15

Facility Location

Courthouse Square

Damper Location

2FL

Inspector Name

Dan Tulcewicz

Damper I.D. #

CHS-2 OA

Damper Type

Vertical Fire Damper

Damper Size

24x10

Damper Manufacturer

Prefco Products

Damper Model #

Unknown

Fusible Link Temperature

165 Degrees

Access Door Size

12x12

Pass / Fail / Abandoned

Pass

Comments / Corrections

None

Exterior Picture of Damper



Interior Picture of Damper



Picture of Damper I.D. Label

