

VISUAL CUYAHOGA COUNTY DAMPER INSPECTION REPORT

Date of Inspection

2022-11-01

Facility Location

Jane Edna Hunter Building

Damper Location

2nd floor
West Mechanical Room

Inspector Name

Dan Tulcewicz

Damper I.D. #

AHU3- Return

Damper Type

Vertical Fire Damper

Damper Size

109x33

Damper Manufacturer

Ruskin

Damper Model #

IBD2

Fusible Link Temperature

165 Degrees

Access Door Size

20x14

Pass / Fail / Abandoned

Pass

Comments / Corrections

None

Exterior Picture of Damper



Interior Picture of Damper



Picture of Damper I.D. Label

