



ADDENDUM No. 7

Date: 1/28/2026
Requisition No. 16306/6753

Due Date: 2/3/2026
Time: 2:00pm

TO: Bidders for: Euclid Beach Connector Trail in the City of Cleveland

FROM: Cuyahoga County
Department of Purchasing

The following are changes/corrections to the above referenced specification package:

- Specification Section 2.1.2.1 lists **limestone and dolomite** among the acceptable stone types for the project, provided they meet durability and testing requirements. However, Specification Section 2.1.3 states that **D1 and D2 Cobble Stone (Rounded Beach Stone) shall be of igneous or metamorphic origin, and that no sedimentary stone is allowed**

Answer:

1. **D1 and D2 cobblestone does not need to be provided by an ODOT-approved supplier.**
2. **Limestone is an acceptable substitute as long as the stone has a minimum specific gravity of 2.6 and material is comprised of naturally rounded stone to the extent feasible.**

THIS DOES NOT CHANGE the due date of 2/3/2026

All remaining terms and conditions of the specification package remain in effect and this addendum therefore becomes part of the specification.

Respectfully submitted,
CUYAHOGA COUNTY

A handwritten signature in blue ink, appearing to read "Paul Porter".

Paul Porter

Cuyahoga County Administrative Headquarters
Department of Purchasing

2079 East 9th Street, Cleveland, Ohio 44115 (216) 443-7200, FAX (216) 443-7206
Ohio Relay Service (TTY) 1-800-750-0750

