

SNOW ROAD REHAB

10/25/24

The plan note on sheet 5 for Construction Noise indicates that no work can be performed at night (between 9p-7:30a). The plan note on sheet 13 for the Phase 3 Sequence of Work states that surface paving and final pavement markings are to be completed during off-peak hours (any hours other than 6a-9a & 4p-7p) or weekend hours. Is it the intent to pave surface course and final pavement marking during the weekend or only between the hours of 9a-4a during the week?

Trent Nissen

Kokosing Construction

Answer

11/1/2024

The requirement to perform the planing and asphalt paving during off-peak hours stated in the Sequence of Construction General Note on Sheet 13 does not apply. This work may be scheduled anytime that satisfies the requirements of the Construction Noise General Note contained on Sheet 5.

11/1/2024

The general summary shows 110 ft of 6" conduit type F, referencing sheets 9 & 10. Sheets 9 & 10 show 10 ft each of the 6" conduit. Please clarify whether the 6" conduit type F shall be 20 ft or 110 ft total

Antonio Rini
The Shelly Company

11/1/2024

Answer: The quantity for Ref. No. 36 - 6" Conduit, Type F for Underdrain Outlets, As Per Plan is 110 FT. This is the quantity contained in the Itemized Unit Price Bid Sheet contained in the Bid Package.