

Lee Road Bridge Rehabilitation

12/5//2025

Questions

1. Sheets 6-7 of 22 show patches at or below ordinary high water. How is it anticipated that the patching work be performed without a 503 cofferdam bid-item?

Means and methods of construction are up to the contractor. Additional accommodation beyond what is shown conceptually in the plans may be required. Any dewatering related should be paid under Item 519 and the contractor should bid accordingly. See revised sheet 3/22 in Addendum #1.

Josh Nemec

J.D. Williamson Construction Co., Inc.