

# CONTRACTOR PRE-BID QUESTION LOG

Project: Ridge Road Resurfacing from Memphis Avenue to Denison Avenue in the Cities Brooklyn and Cleveland

---

Bid Due: February 11, 2020 RQ: 47718

## **January 21, 2020 (Ambrose Industries)**

Do you anticipate extending the bid due date?

No, we do not anticipate extending the bid due date.

What additional details are you willing to provide, if any, beyond what is stated in bid documents concerning how you will identify the winning bid?

The contract award is based on the lowest and best bid.

Was this bid posted to the nationwide free bid notification website at [www.mygovwatch.com](http://www.mygovwatch.com)

No, we do not post on [www.mygovwatch.com](http://www.mygovwatch.com).

Other than your own website, where was this bid posted?

Our projects are posting on Builders Exchange and Construct Connect.

## **February 5, 2020 (Shelly Company)**

- Ref #16 – 2” Asphalt Conc Walk – 3000 SF – Where is this intended to be used. It is not called out in the plans anywhere.

Item is to be utilized as directed by the engineer to maintain pedestrian traffic when existing sidewalk is disturbed by construction activities.

- Ref #56 – PDR (442), APP – 2000 SY – What material would the County like to be used to fill these repairs?

Replacement material shall conform to Item 442 as specified in the plans (Reference No. 56, Item 251 – Partial Depth Repair (442), As Per Plan and its corresponding general note on sheet 16/28).