



PLAN

**NOTES:** The cylindrical section of the Manhole shall be extended vertically from the shelves for the distance equal to the internal diameter of the Largest Pipe entering the Manhole, with a minimum vertical height of 4' - 0".

BRICK DROP MANHOLE  
FOR STORM SEWER

REVISIONS:	SCALE NO SCALE	DATE: OCTOBER 2021
------------	-------------------	--------------------